

Central Kansas Fire Marshal's Mobile Food Truck Inspection

Vendor Name/Permit number _____

Electrical

- | | | | |
|---|-----|----|----|
| 1. No exposed wiring or splices..... | YES | NO | NA |
| 2. Extension cord grounded, proper ampacity, no damage..... | YES | NO | NA |
| 3. No "daisy chaining, "piggybacking," or multiplug adapters..... | YES | NO | NA |

Compressed Gas (Liquid Propane)

- | | | | |
|--|-----|----|----|
| 1. Bottles Secured with restraints in upright position..... | YES | NO | NA |
| 2. If designed, 200 lbs. LP; if not, 100 lbs. LP aggregate in use..... | YES | NO | NA |
| 3. Protective devices and/or caps in place over valves..... | YES | NO | NA |
| 4. Adequate condition of tanks & piping..... | YES | NO | NA |
| 5. LP Gas Detector/Alarm..... | YES | NO | NA |

Compressed Gas Appliances

- | | | | |
|---|-----|----|----|
| 1. Gas Cooking appliances secured in place..... | YES | NO | NA |
| 2. Gas appliances connected to piping with ANSI-listed connector. | YES | NO | NA |

Cooking Safety - Grease Laden Vapors

- | | | | |
|--|-----|----|----|
| 1. Type I hood system with suppression, adequately cleaned..... | YES | NO | NA |
| 2. Suppression system inspected bi-annually and tagged | YES | NO | NA |
| 3. Class K portable extinguisher inspected annually and tagged ... | YES | NO | NA |

Fire Safety

- | | | | |
|--|-----|----|----|
| 1. Type II hood system for warming or steam (if required) | YES | NO | NA |
| 2. Min. 2A-10BC fire extinguisher inspected annually and tagged... | YES | NO | NA |

License and Permits

- | | | | |
|--|-----|----|----|
| 1. KS Dept. of Agriculture License for edible food vendors..... | YES | NO | NA |
| <i>Green sticker in Electrical Panel & Visible License. Permit #</i> | | | |

Fire Inspector

Vendor

Date